



NOTE: POLYSULFIDE SEALANT WIDTH TO DEPTH RATIO SHOWN IS APPROXIMATELY 2:1. DETAIL CAN BE BUILT BY INSTALLING CONTAINMENT LINING SYSTEM OVER JOINT, RESAWCUTTING, AND INSTALLING BACKER ROD AND SEALANT.

TNEMEC
STANDARD SECONDARY CONTAINMENT LINING DETAILS

EXPANSION/ISOLATION JOINT TREATMENT DETAIL

SCS-07

REV.0